



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

**Quarterly Report for the Baxter
Water Treatment and Distribution System
Waterworks # 260001013**

Operated by the Ontario Clean Water Agency (OCWA)
under contract to the Township of Essa
for the period ending March 31 , 2002

Introduction:

This report is a summary of the water quality during the first quarter of 2002, published in accordance with Ontario Regulation 450/00 titled “**Drinking Water Protection - Larger Water Works**”. It includes important information regarding the source of your water, analytical test results, and how it compares to standards set by the Province. If you have any questions regarding this report, please contact our Client Services Representative listed in Section 3 below.

During this quarter, more than 300 tests for water quality parameters specified in Ontario Regulation 459/00 and the facility Certificate of Approval (C of A) were conducted at Lakefield Research, an accredited laboratory under contract with OCWA. Of the tests conducted on treated water during this quarter, there were no exceedances reported.

Compliance With Provincial Regulations:

OCWA operates your water facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs:** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators:** Your water treatment plant and distribution system is operated and maintained by OCWA’s competent and licensed staff. The mandatory licensing program for operators of drinking water facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical Requirements:** OCWA collects samples from the plant and distribution system to meet the requirements listed in Schedule 2 of Ontario Regulation 459/00 and any additional parameters required by the facility C of A. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures:** To ensure the protection of the public health and operational excellence, OCWA adheres to the guidelines and procedures developed by the Ministry of Environment and the Ministry of Health.

System Information:

Facility Name:	Baxter Water System	Client Services:	Steve Rohacek
Total Design Capacity:	1048m ³ /day	Phone Number:	(519)770-5699
Raw Water Source:	Two wells	E-mail Address:	srohacek@OCWA.com
Disinfection Method:	Sodium hypochlorite	Operations Manager:	Wayne White
Municipal Location:	Township of Essa	Phone Number:	(705)429-2525
Service Area:	Village of Baxter	E-mail Address:	wwhite@OCWA.com
Service Population:	114	Office Address:	Wasaga Beach, ON

Operational Description: Two drilled wells provide 255 m³/day potable water to a community of 114. As water is pumped from either well, sodium hypochlorite is injected prior to flowing to four (4) 425 litre pressure tanks and out into the system. Online chlorine and turbidity analyzers continuously monitor the residual and clarity in the water and sends an alarm if the predetermined set points are exceeded.

Analytical Test Results:

Micro biological Parameters	January	February	March	Quarter Summary	MAC / IMAC
Total Coliform counts/100mls					
Number of Samples	25	20	20	65	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0		0
Exceedences	0	0	0	0	
E. Coli counts/100mls					
Number of Samples	25	20	20	65	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0		0
Exceedences	0	0	0	0	
Background					
Number of Samples	21	10	8	39	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	200
Exceedences	0	0	0	0	

Typical sources of microbial contaminants, such as viruses and bacteria, may come from septic systems, agricultural livestock operations, wildlife, and wastewater treatment plants.

Comments: THERE WERE NO EXCEEDENCES IN THE MICROBIOLOGICAL PARAMETERS TESTED DURING THIS QUARTER.

Operational Parameters	January	February	March	Quarter Summary	MAC / IMAC
Chlorine Residual (Plant)					
Number of Samples	31	28	31	90	
Number of Detectable Results	31	28	31	90	.05/4.0 Free
Min / Max	0.05/2.50	0.23/1.90	0.22/1.41	0/2.12	.25 /3.0 Combined
Exceedances	2	2	1	5	
Chlorine Residual (System)					
Number of Samples	10	8	8		
Number of Detectable Results	10	8	8		.05/4.0 Free
Min/Max	.06/2.2	.23/1.70	.10/1.23	.06/2.22	.25 /3.0 Combined
Exceedances	0	0	0	0	
Turbidity					
Number of Samples	31	28	31	90	
Number of Detectable Results	31	28	31	90	
Min / Max	.37/1.24	.32/ 1.38	.56/1.8	.32/1.80	1
Exceedances	7	4	7	18	
COMMENTS: Turbidity and chlorine are monitored continuously with online equipment and are alarmed. Operations staff collect grab samples during their plant checks and measure the chlorine and turbidity with pocket instruments as a comparison to the continuous equipment. All operational parameter exceedances were reported as per O.Reg. 459/00.					

Volatile Organic Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.</i>					
Comments: VOLATILE ORGANIC PARAMETERS WERE TESTED IN JANUARY AND THERE WERE NO EXCEEDANCES REPORTED.					

Inorganic Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil & gas production, mining.</i>					
Comments: INORGANIC PARAMETERS WERE NOT TESTED DURING THIS QUARTER.					

Pesticides and PCB Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of contamination from pesticides and herbicides, may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.</i>					
Comments: PESTICIDES AND PCB's WERE TESTED IN JANUARY AND THERE WERE NO EXCEEDANCES REPORTED.					

Radiological Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of contamination are from man made or natural elements emitting radiation in the form of alpha, beta or gamma particles</i>					
Comments: RADIOLOGICAL PARAMETERS WERE NOT TESTED DURING THIS QUARTER.					

Discussion of Analytical Results:

During this quarter, there were no micro biological parameters that exceeded the MAC/IMAC limits. In respect to Operational Parameters, 18 turbidity exceedences were reported as per Regulation 459/00. These samples are taken continuously in-house by online equipment and these instantaneous spikes are believed to be caused from the starting and stopping of pumps, equipment maintenance/calibration and/or air and a buildup of iron sediment in the sample lines. During these spikes, the system was being adequately disinfected; therefore, reducing any risks that may be associated with the high turbidity. The turbidity analyzers are alarmed to notify Operations Staff of continual exceedances.

On January 17, 2002, an Adverse Notification was issued for low combined chlorine level leaving the Baxter Pumphouse due to a chlorine pump malfunction. The equipment was repaired and the chlorine level was restored immediately. When Operations Staff are unable to detect a free chlorine residual due to the formation of chloramines in the water supply, they calculate the combined chlorine residual. If the combined concentration is < .25 mg/L, it must be reported as adverse which was the case with the incident referenced above.

All other volatile, organic and inorganic and pesticide parameters tested in this quarter were within the limits specified in Table 1 of ON Reg.459/00.

Availability of Analytical Test Results:

The certificate of approval from the Ministry of the Environment, and Regulation 459/00 set out monitoring requirements for your water. The tables above summarize all the results required for inclusion in quarterly reports. Your water is extensively tested for the presence of dozens of compounds. Some compounds, not listed above, may be present in low concentrations and their presence does not necessarily mean that the water poses a health risk. Results of all analytical tests are available through your municipal office and OCWA.

Definitions and Abbreviations:

- **MAC** - Maximum Acceptable Concentration.
- **IMAC** - Interim Maximum Acceptable Concentration.
- **Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.
- **Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.
- **Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.
- **Organic Parameter** - a group of chemical compounds containing carbon.
- **Inorganic Parameter** - a group of chemical compounds not containing carbon.
- **Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.
- **Combined Chlorine Residual** - total chlorine residual minus free chlorine residual
- **Chloramines** - chloramines are produced when ammonia is added to chlorinated water during the disinfection process.



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

**Quarterly Report for the Baxter
Water Treatment and Distribution System
Waterworks # 260001013**

Operated by the Ontario Clean Water Agency (OCWA)
under contract to the Township of Essa
for the period ending March 31 , 2002

Introduction:

This report is a summary of the water quality during the first quarter of 2002, published in accordance with Ontario Regulation 450/00 titled “**Drinking Water Protection - Larger Water Works**”. It includes important information regarding the source of your water, analytical test results, and how it compares to standards set by the Province. If you have any questions regarding this report, please contact our Client Services Representative listed in Section 3 below.

During this quarter, more than 300 tests for water quality parameters specified in Ontario Regulation 459/00 and the facility Certificate of Approval (C of A) were conducted at Lakefield Research, an accredited laboratory under contract with OCWA. Of the tests conducted on treated water during this quarter, there were no exceedances reported.

Compliance With Provincial Regulations:

OCWA operates your water facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs:** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators:** Your water treatment plant and distribution system is operated and maintained by OCWA’s competent and licensed staff. The mandatory licensing program for operators of drinking water facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical Requirements:** OCWA collects samples from the plant and distribution system to meet the requirements listed in Schedule 2 of Ontario Regulation 459/00 and any additional parameters required by the facility C of A. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures:** To ensure the protection of the public health and operational excellence, OCWA adheres to the guidelines and procedures developed by the Ministry of Environment and the Ministry of Health.

System Information:

Facility Name:	Baxter Water System	Client Services:	Steve Rohacek
Total Design Capacity:	1048m ³ /day	Phone Number:	(519)770-5699
Raw Water Source:	Two wells	E-mail Address:	srohacek@OCWA.com
Disinfection Method:	Sodium hypochlorite	Operations Manager:	Wayne White
Municipal Location:	Township of Essa	Phone Number:	(705)429-2525
Service Area:	Village of Baxter	E-mail Address:	wwhite@OCWA.com
Service Population:	114	Office Address:	Wasaga Beach, ON

Operational Description: Two drilled wells provide 255 m³/day potable water to a community of 114. As water is pumped from either well, sodium hypochlorite is injected prior to flowing to four (4) 425 litre pressure tanks and out into the system. Online chlorine and turbidity analyzers continuously monitor the residual and clarity in the water and sends an alarm if the predetermined set points are exceeded.

Analytical Test Results:

Micro biological Parameters	January	February	March	Quarter Summary	MAC / IMAC
Total Coliform counts/100mls					
Number of Samples	25	20	20	65	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0		0
Exceedences	0	0	0	0	
E. Coli counts/100mls					
Number of Samples	25	20	20	65	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0		0
Exceedences	0	0	0	0	
Background					
Number of Samples	21	10	8	39	
Number of Detectable Results	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	200
Exceedences	0	0	0	0	

Typical sources of microbial contaminants, such as viruses and bacteria, may come from septic systems, agricultural livestock operations, wildlife, and wastewater treatment plants.

Comments: THERE WERE NO EXCEEDENCES IN THE MICROBIOLOGICAL PARAMETERS TESTED DURING THIS QUARTER.

Operational Parameters	January	February	March	Quarter Summary	MAC / IMAC
Chlorine Residual (Plant)					
Number of Samples	31	28	31	90	
Number of Detectable Results	31	28	31	90	.05/4.0 Free
Min / Max	0.05/2.50	0.23/1.90	0.22/1.41	0/2.12	.25 /3.0 Combined
Exceedances	2	2	1	5	
Chlorine Residual (System)					
Number of Samples	10	8	8		
Number of Detectable Results	10	8	8		.05/4.0 Free
Min/Max	.06/2.2	.23/1.70	.10/1.23	.06/2.22	.25 /3.0 Combined
Exceedances	0	0	0	0	
Turbidity					
Number of Samples	31	28	31	90	
Number of Detectable Results	31	28	31	90	
Min / Max	.37/1.24	.32/ 1.38	.56/1.8	.32/1.80	1
Exceedances	7	4	7	18	
COMMENTS: Turbidity and chlorine are monitored continuously with online equipment and are alarmed. Operations staff collect grab samples during their plant checks and measure the chlorine and turbidity with pocket instruments as a comparison to the continuous equipment. All operational parameter exceedances were reported as per O.Reg. 459/00.					

Volatile Organic Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.</i>					
Comments: VOLATILE ORGANIC PARAMETERS WERE TESTED IN JANUARY AND THERE WERE NO EXCEEDANCES REPORTED.					

Inorganic Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil & gas production, mining.</i>					
Comments: INORGANIC PARAMETERS WERE NOT TESTED DURING THIS QUARTER.					

Pesticides and PCB Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of contamination from pesticides and herbicides, may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.</i>					
Comments: PESTICIDES AND PCB's WERE TESTED IN JANUARY AND THERE WERE NO EXCEEDANCES REPORTED.					

Radiological Parameters	January	February	March	Quarter Summary	MAC / IMAC
<i>Typical sources of contamination are from man made or natural elements emitting radiation in the form of alpha, beta or gamma particles</i>					
Comments: RADIOLOGICAL PARAMETERS WERE NOT TESTED DURING THIS QUARTER.					

Discussion of Analytical Results:

During this quarter, there were no micro biological parameters that exceeded the MAC/IMAC limits. In respect to Operational Parameters, 18 turbidity exceedences were reported as per Regulation 459/00. These samples are taken continuously in-house by online equipment and these instantaneous spikes are believed to be caused from the starting and stopping of pumps, equipment maintenance/calibration and/or air and a buildup of iron sediment in the sample lines. During these spikes, the system was being adequately disinfected; therefore, reducing any risks that may be associated with the high turbidity. The turbidity analyzers are alarmed to notify Operations Staff of continual exceedances.

On January 17, 2002, an Adverse Notification was issued for low combined chlorine level leaving the Baxter Pumphouse due to a chlorine pump malfunction. The equipment was repaired and the chlorine level was restored immediately. When Operations Staff are unable to detect a free chlorine residual due to the formation of chloramines in the water supply, they calculate the combined chlorine residual. If the combined concentration is < .25 mg/L, it must be reported as adverse which was the case with the incident referenced above.

All other volatile, organic and inorganic and pesticide parameters tested in this quarter were within the limits specified in Table 1 of ON Reg.459/00.

Availability of Analytical Test Results:

The certificate of approval from the Ministry of the Environment, and Regulation 459/00 set out monitoring requirements for your water. The tables above summarize all the results required for inclusion in quarterly reports. Your water is extensively tested for the presence of dozens of compounds. Some compounds, not listed above, may be present in low concentrations and their presence does not necessarily mean that the water poses a health risk. Results of all analytical tests are available through your municipal office and OCWA.

Definitions and Abbreviations:

- **MAC** - Maximum Acceptable Concentration.
- **IMAC** - Interim Maximum Acceptable Concentration.
- **Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.
- **Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.
- **Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.
- **Organic Parameter** - a group of chemical compounds containing carbon.
- **Inorganic Parameter** - a group of chemical compounds not containing carbon.
- **Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.
- **Combined Chlorine Residual** - total chlorine residual minus free chlorine residual
- **Chloramines** - chloramines are produced when ammonia is added to chlorinated water during the disinfection process.