

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	220003902
Drinking-Water System Name:	Thornton (Camilla) Well Supply System
Drinking-Water System Owner:	Corporation Township of Essa
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2003 through December 31, 2003

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Municipal Offices Corporation Township of Essa 5786 Simcoe County Rd. 21 Utopia, Essa Twp., Ontario L0M 1T0 </div> <p>Website: www.essatownship.on.ca</p>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; padding: 2px; width: fit-content;">None</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] <u>N/A</u></p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; padding: 2px; width: fit-content;">None</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [] <u>N/A</u></p>
---	---

List Drinking-Water Systems, which receive all of their drinking water from your system:

N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [] N/A

Indicate how you notified system users that your annual report is available, and is free of charge.

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office

- Public access/notice via a newspaper
 Public access/notice via Public Request
 Public access/notice via a Public Library
 Public access/notice via other method Notice made on water bills

Describe your Drinking-Water System

The Camilla Water System provided potable water to approximately 112 connections in the eastern portion of Thornton. This plant was originally part of Innisfil Township and was taken over by Essa Township during the 1994 amalgamation. Three drilled wells equipped with submersible pumps supplied up to 655 m3 per day. The control building houses twelve 450 litre pressure tanks as well as a hypochlorination system which provided disinfection to the water supply. On-line analyzers continuously monitored the chlorine and turbidity; an alarm was signaled if the levels fell below or exceeded the pre-set values. The daily flow was measured with a 3 inch Rockwell Turbo Meter and a stand-by generator was available as a back-up power source in the event of a power failure.

Following the completion of upgrades to the Glen Avenue pumphouse, the Camilla Well Supply was decommissioned December 23, 2004, as per Facility Certificates of Approvals and Permits.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite 12% Solution NSF, Disinfection

Were any significant expenses incurred to?

- Install required equipment
 Repair required equipment
 Replace required equipment

Describe

The submersible well pump for Well 3 was rebuilt.

All routine and preventative maintenance was conducted as schedule.

Drinking-Water Systems Regulation O. Reg. 170/03

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre?

Incident Date mm/dd/yy	Parameter	Result	Unit of Meas.	Corrective Action	Corrective Action Date mm/dd/yy
01/07/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 1.10mg/l.	01/10/03
01/09/03	Turbidity TDW	1.2	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 1.3mg/l.	01/10/03
01/11/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 1.07mg/l.	01/11/03
01/18/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 0.93mg/l.	01/18/03
02/10/03	Turbidity TDW	>1	NTU	Instantaneous spike. Analyzer Flushed and Cleaned. Turbidity restored to 0.3NTU. Reported as per 459/00 F.A.C. @ Time of exceedence 1.29mg/l.	02/10/03
02/12/03	Turbidity TDW	>1	NTU	Instantaneous spike. Analyzer Flushed and Cleaned. Turbidity restored to 0.3NTU. Reported as per 459/00 F.A.C. @ Time of exceedence 0.81mg/l.	02/12/03
02/22/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00	02/22/03
04/22/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 0.87mg/l.	04/23/03
04/28/03	Turbidity TDW	>1	NTU	Instantaneous spike Reported as per 459/00 F.A.C. @ Time of exceedence 1.29mg/l.	04/29/03
08/26/03	Sodium	23.4	mg/l	Reported as per O.Reg 170 to MOH and MOE, Aug 29, 2003, AWQI 15509. Resamples collected	09/11/03

				September 2, 2003. Resample did not exceed MAC 19.3 mg/l. Issue of Resolution submitted Sept. 11, 2003.	
10/14/03	DDW Bacti Sample TC Background Colonies	246	CFU/ 100ml	Reported as per O.Reg 170 to MOH and MOE, October 16, 2003, AWQI #18358. Set of Resamples collected October 16, 2003. Resamples showed no further indication adverse water, Issue of Resolution provided October 21, 2003.	10/16/03

Microbiological testing done under section 8 (2) during this reporting period

	Number of Samples	Range of E.Coli or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of Background Samples	Range of Background Results (#-#)
Raw	106	0 - 0	0 - 5	N/A	N/A
Treated	52	0 - 0	0 - 0	52	0 - 3
Distribution	107	0 - 0	0 - 0	55	0 - 246

This Sampling was conducted as follows:
Microbiological parameters: RWW P1 (Raw Well Water)

Micro biological Parameters	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Total Coliform														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	1	2	0	0	0	3	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/5	0/6	0/0	0/0	0/0	0/6	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
E. Coli														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	

Drinking-Water Systems Regulation O. Reg. 170/03
Microbiological parameters: RWW P2 (Raw Well Water)

Micro biological Parameters	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Total Coliform														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	1	1	0	0	0	2	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/5	0/2	0/0	0/0	0/0	0/5	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
E. Coli														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	

Microbiological parameters: RWW P3 (Raw Well Water)

Micro biological Parameters	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Total Coliform														
# Samples	2	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	2	
# Detectable	0												0	
Min / Max	0/0												0/0	
Exceedences	0												0	
E. Coli														
# Samples	2	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	2	
# Detectable	0												0	
Min / Max	0/0												0/0	
Exceedences	0												0	

Microbiological Parameters: TDW Pumphouse (Treated Drinking Water)

Micro biological Parameters	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Total Coliform														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
E. Coli														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
Background														
# Samples	5	4	5	4	4	4	5	4	5	4	4	4	52	
# Detectable	0	0	0	0	0	0	0	0	2	0	0	0	2	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/3	0/0	0/0	0/0	0/3	
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	

Microbiological parameters: DDW Camilla Distribution System

Micro biological Parameters	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Total Coliform														
# Samples	10	8	10	8	8	8	10	8	10	11	8	8	107	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
E. Coli														
# Samples	10	8	10	8	8	8	10	8	10	11	8	8	107	
# Detectable	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
Background														
# Samples	5	4	5	4	4	4	5	4	5	7	4	4	55	
# Detectable	0	0	0	0	0	0	0	1	0	1	0	0	2	
Min / Max	0/0	0/0	0/0	0/0	0/0	0/0	0/0	0/1	0/0	0/246	0/0	0/0	0/246	200
Exceedences	0	0	0	0	0	0	0	0	0	1	0	0	1	

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

The Thornton Camilla Watersystem, Township of Essa was equipped with Free Available Chlorine residual (mg/l) and Turbidity (NTU) continuous monitoring equipment analyzing the Treated Drinking Water. At both facilities, the continuous monitoring equipment is installed and operated in the treatment process at a location where the intended contact time has been completed, prior to entering the distribution system. As requested the following Table summarizes data collected by this continuous monitoring equipment:

Treated Drinking Water Camilla	Number of Grab Samples	Range of Results (#-#)
Turbidity NTU	8760	0.012 - >1.0
Chlorine	8760	0.65-2.02
Fluoride (If the DWS provides fluoridation)	N/A	N/A

***NOTE:** For continuous monitors use 8760 as the number of samples.*

***NOTE:** Record the unit of measure if it is **not** milligrams per litre.*

In addition to the continuous monitoring the following tables summarize additional sampling carried out in regards to Schedule 7:

Chlorine residuals	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Free Chlorine Residual mg/l (Treated Camilla)														
Number of Samples	31	28	31	30	31	30	31	31	30	31	30	22	356	
Number of Detectable Results	31	28	31	30	31	30	31	31	30	31	30	22	356	
Min/Max	0.75/1.44	0.65/1.95	0.72/1.34	0.78/1.36	1.1/1.78	1.02/1.95	0.82/1.86	0.95/1.67	0.92/1.69	1.08/2.01	1.15/1.83	1.38/2.02	0.65/2.02	0.05/3.99
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
Free Chlorine Residual mg/l (Systeml)														
Number of Samples	10	8	10	8	8	34	36	35	35	36	34	26	280	
Number of Detectable Results	10	8	10	8	8	34	36	35	35	36	34	26	280	
Min/Max	0.58/1.1	0.56/0.68	0.6/0.97	0.47/0.98	0.57/1.03	0.40/1.39	0.6/1.47	0.39/1.22	0.86/1.47	0.59/1.61	0.58/1.46	0.46/1.9	0.39/1.61	0.05/3.99
Exceedences	0	0	0	0	0	0	0	0	0	0	0	0	0	
Turbidity	Jan.	Feb.	Mar	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Reporting Period Summary	MAC / IMAC
Turbidity (RWW P1) NTU														
Number of Samples						1	1	1	4	2	4	1	14	
Min/Max						0.81	0.87	2.36	0.16/0.47	0.23/0.37	0.21/0.47	0.25	0.16/2.36	
Turbidity (RWW P2) NTU														
Number of Samples						1	1	1	4	2	4	1	14	
Min/Max						.16	0.88	1.09	0.11/0.21	0.27/0.64	0.34/0.58	0.31	0.11/0.31	
Turbidity (RWW P3) NTU														
Number of Samples						Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service	Well Out of Service		
Min/Max														

Drinking-Water Systems Regulation O. Reg. 170/03

Turbidity (Treated Camilla) NTU														
Number of Samples	31	28	31	30	31	30	31	31	30	31	30	23	357	
Min/Max	0.04/ >1.0	0.012/ >1.0	0.02/ 0.13	0.06/ >1.0	0.05/ 0.21	0.06/ 0.08	0.05/ 0.23	0.06/ 0.19	0.06/ 0.41	0.06/ 0.4	0.06/ 0.13	0.05/ 0.15	0.012/ >1.0	1.0
Exceedences	4	3	0	2	0	0	0	0	0	0	0	0	9	

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Facility Certificate of Approval #9354-56PK9W, issued February 7, 2002

And CofA # 1490-PJJEZ, issued July 25, 2003.

Parameter	Sample Date mm/dd/y	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Unit of Meas.	Exceedences
Raw Well Water Well 1 RWW P1 Organic Nitrogen	01/20/03	0.04	04/28/03	0.08	08/26/03	0.34	10/27/03	0.05	mg/l	0
Ammonia + Ammonium			04/28/03	0.06	08/26/03	0.1	10/27/03	0.18	mg/	0
TKN			04/28/03	0.14	08/26/03	0.44	10/27/03	0.14	mg/	0
Sodium	01/20/03	22.6	04/28/03	21.8	08/26/03	21.7	10/27/03	18.1	mg/l	0
Nitrite	01/20/03	0.011	04/28/03	0.011	08/26/03	0.011	10/27/03	0.011	mg/l	0
Nitrate	01/20/03	7.19	04/28/03	6.56	08/26/03	6.64	10/27/03	6.0	mg/l	0
Nitrate +Nitrite	01/20/03	7.19	04/28/03	6.56	08/26/03	6.64	10/27/03	6.0	mg/l	0
Raw Well Water Well 2 RWW P2 Organic Nitrogen	01/20/03	0.04	04/28/03	0.04	08/26/03	0.33	10/27/03	0.12	mg/l	0
Ammonia + Ammonium			04/28/03	0.17	08/26/03	0.18	10/27/03	0.1	mg/	0
TKN			04/28/03	0.09	08/26/03	0.51	10/27/03	0.22	mg/	0
Sodium	01/20/03	22.7	04/28/03	23.9	08/26/03	22.1	10/27/03	17.8	mg/	0
Nitrite	01/20/03	0.011	04/28/03	0.011	08/26/03	0.011	10/27/03	0.011	mg/l	0
Nitrate	01/20/03	7.21	04/28/03	7.51	08/26/03	10.4	10/27/03	6.12	mg/l	0
Nitrate +Nitrite	01/20/03	7.21	04/28/03	7.51	08/26/03	10.4	10/27/03	6.12	mg/l	0
Raw Well Water Well 3 RWW P3	Well Out of Service		Well Out of Service		Well Out of Service		Well Out of Service			

Summary of Inorganic parameters tested during this reporting period or most recent at the Camilla Thornton Facility

Parameter	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Unit of Meas.	Exceedances
Antimony					08/26/03	0.6			ug/l	0
Arsenic					08/26/03	2.0			ug/l	0
Barium					08/26/03	77.0			ug/l	0
Boron					08/26/03	11.0			ug/l	0
Cadmium					08/26/03	0.1			ug/l	0
Chromium					08/26/03	4.0			ug/l	0
Lead					09/30/03	1.2			ug/l	0
Mercury					08/26/03	0.1			ug/l	0
Selenium					08/26/03	3.0			ug/l	0
Uranium					08/26/03	0.05			ug/l	0
Sodium					08/26/03	23.4			mg/l	0
Fluoride					08/26/03	0.04			mg/l	0
Nitrite	01/20/03	0.011	04/28/03	0.011	08/26/03	0.011	10/27/03	0.011	mg/l	0
Nitrate	01/20/03	7.21	04/28/03	6.51	08/26/03	6.61	10/27/03	6.02	mg/l	0

Summary of Organic parameters sampled during this reporting period or most recent at the Camilla Thornton Facility

Parameter	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Sample Date (mm/dd/yy)	Result Value	Unit of Meas	Exceed.
Alachlor	01/20/03	0.09	04/28/03	0.09					ug/l	0
Aldicarb	01/20/03	0.76	04/28/03	0.76					ug/l	0
Aldrin + Dieldrin	01/20/03	0.05	04/28/03	0.05					ug/l	0
Atrazine + N-dealkylated metabolites	01/20/03	0.43	04/28/03	0.43					ug/l	0
Azinphos-methyl	01/20/03	0.59	04/28/03	0.59					ug/l	0
Bendiocarb	01/20/03	0.27	04/28/03	0.27					ug/l	0
Benzene	01/20/03	0.36	04/28/03	0.36					ug/l	0
Benzo(a)pyrene					08/26/03	0.004			ug/l	0
Bromoxynil	01/20/03	0.06	04/28/03	0.06					ug/l	0
Carbaryl	01/20/03	0.14	04/28/03	0.14					ug/l	0
Carbofuran	01/20/03	0.14	04/28/03	0.14					ug/l	0
Carbon Tetrachloride	01/20/03	0.34	04/28/03	0.34					ug/l	0
Chlordane (Total)	01/20/03	0.2	04/28/03	0.2					ug/l	0
Chlorpyrifos	01/20/03	1.2	04/28/03	1.2					ug/l	0
Cyanazine	01/20/03	0.079	04/28/03	0.079					ug/l	0
Diazinon	01/20/03	0.41	04/28/03	0.41					ug/l	0
Dicamba	01/20/03	0.9	04/28/03	0.9					ug/l	0
1,2-Dichlorobenzene	01/20/03	0.56	04/28/03	0.56					ug/l	0
1,4-Dichlorobenzene	01/20/03	0.25	04/28/03	0.25					ug/l	0
Dichlorodiphenyltrichloroethane (DDT) + metabolites	01/20/03	0.46	04/28/03	0.46					ug/l	0

1,2-Dichloroethane	01/20/03	0.32	04/28/03	0.32					ug/l	0
1,1-Dichloroethylene (vinylidene chloride)	01/20/03	0.52	04/28/03	0.52					ug/l	0
Dichloromethane	01/20/03	1.17	04/28/03	1.17					ug/l	0
2,4-Dichlorophenol	01/20/03	0.15	04/28/03	0.15					ug/l	0
2,4-Dichlorophenoxy acetic acid (2,4-D)	01/20/03	0.33	04/28/03	0.33					ug/l	0
Diclofop-methyl	01/20/03	0.84	04/28/03	0.84					ug/l	0
Dimethoate	01/20/03	0.1	04/28/03	0.1					ug/l	0
Dinoseb	01/20/03	0.42	04/28/03	0.42					ug/l	0
Diquat	01/20/03	1.0	04/28/03	1.0					ug/l	0
Diuron	01/20/03	0.66	04/28/03	0.66					ug/l	0
Glyphosate	01/20/03	6.0	04/28/03	6.0					ug/l	0
Heptachlor + Heptachlor Epoxide	01/20/03	0.2	04/28/03	0.2					ug/l	0
Linadane (Total)	01/20/03	0.13	04/28/03	0.13					ug/l	0
Malathion	01/20/03	0.37	04/28/03	0.37					ug/l	0
Methoxychlor	01/20/03	0.64	04/28/03	0.64					ug/l	0
Metolachlor	01/20/03	0.58	04/28/03	0.58					ug/l	0
Metribuzin	01/20/03	0.5	04/28/03	0.5					ug/l	0
Monochlorobenzene	01/20/03	0.46	04/28/03	0.46					ug/l	0
Paraquat	01/20/03	1.0	04/28/03	1.0					ug/l	0
Parathion	01/20/03	1.2	04/28/03	1.2					ug/l	0
Pentachlorophenol	01/20/03	0.15	04/28/03	0.15					ug/l	0
Phorate	01/20/03	0.73	04/28/03	0.73					ug/l	0
Picloram	01/20/03	0.19	04/28/03	0.19					ug/l	0
Polychlorinated Biphenyls(PCB)	01/20/03	0.04	04/28/03	0.04					ug/l	0
Promethyne	01/20/03	0.16	04/28/03	0.16					ug/l	0
Simazine	01/20/03	0.18	04/28/03	0.18					ug/l	0
THM DDW	01/20/03	9.0	04/28/03	7.3	10/27/03	7.5	10/27/03	5.2	ug/l	0
THM TDW Camilla	01/20/03	.63	04/28/03	.63					ug/l	0
Temphos	01/20/03	0.25	04/28/03	.25					ug/l	0
Terbufos	01/20/03	0.73	04/28/03	0.73	09/30/03	0.7			ug/l	0
Tetrachloroethylene	01/20/03	0.48	04/28/03	0.48					ug/l	0
2,3,4,6-Tetrachlorophenol	01/20/03	0.14	04/28/03	0.14					ug/l	0
Triallate	01/20/03	0.14	04/28/03	0.14					ug/l	0
Trichloroethylene	01/20/03	0.48	04/28/03	0.48					ug/l	0
2,4,6-Trichlorophenol	01/20/03	0.25	04/28/03	0.25					ug/l	0

2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	01/20/03	0.47	04/28/03	0.47					ug/l	0
Trifluralin	01/20/03	0.35	04/28/03	0.35					ug/l	0
Vinyl Chloride	01/20/03	0.08	04/28/03	0.08					ug/l	0

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if category is large municipal residential, small municipal residential, large municipal non residential, small municipal non residential, large non municipal non residential)